

11.8: Transmission Line with Losses

The voltage and current on a lossless transmission line must satisfy the following equations:

$$\begin{aligned}\frac{\partial^2 V}{\partial z^2} &= \epsilon\mu_0 \frac{\partial^2 V}{\partial t^2}, \\ \frac{\partial^2 I}{\partial z^2} &= \epsilon\mu_0 \frac{\partial^2 I}{\partial t^2}.\end{aligned}\quad (11.8.1)$$

These are a direct consequence of Maxwell's equations. Strictly speaking, they are only correct providing that ϵ , the dielectric constant, is truly a constant and therefore independent of frequency. Even the best of dielectric insulating materials exhibit some losses that are frequency dependent: in many cases the imaginary part of the dielectric constant is proportional to the frequency. For a time dependence $\exp(i\omega t)$ the above two equations, (11.8.1), become

$$\begin{aligned}\frac{\partial^2 V}{\partial z^2} &= -\epsilon\mu_0\omega^2 V, \\ \frac{\partial^2 I}{\partial z^2} &= -\epsilon\mu_0\omega^2 I,\end{aligned}\quad (11.8.2)$$

where ϵ may have real and imaginary parts, both of which will depend upon the frequency. Solutions of Equations (11.8.2) that are harmonic in space, i.e. V and I are proportional to $\exp(-ikz)$, must be described by a wave-vector k that satisfies the condition

$$k^2 = \epsilon\mu_0\omega^2,$$

In the presence of dielectric losses ϵ will in general be a complex quantity, and therefore so also must the wave-vector be complex :

$$k = \pm\omega\sqrt{\epsilon\mu_0}\quad (11.8.3)$$

so that

$$k = \pm(k_1 - ik_2). \quad (11.8.4)$$

The general solutions of the wave equations (11.8.2) for the voltage and current on the transmission line in the presence of a lossy dielectric can be written

$$\begin{aligned}V(z, t) &= [a \exp(-k_2 z) \exp(-ik_1 z) + b \exp(k_2 z) \exp(ik_1 z)] \cdot \exp(i\omega t), \\ I(z, t) &= \frac{1}{Z_0} [a \exp(-k_2 z) \exp(-ik_1 z) - b \exp(k_2 z) \exp(ik_1 z)] \exp(i\omega t),\end{aligned}\quad (11.8.5)$$

where $(k_2/k_1) \ll 1$ for a high quality cable, and k_1, k_2 are the real and imaginary parts of the wave-vector. Notice that k_2 must be positive in order that the amplitude of the forward propagating wave decays with distance.

In actual fact, part of the energy loss as a wave propagates down a transmission line is due to Ohmic losses in the skin-depth of the conductors: i.e. the metal electrodes do possess a finite conductivity and therefore there are energy losses due to the shielding currents that flow in them. It can be easily shown, using the methods of Chapter(10), that the rate of energy loss in each conductor per unit area of surface is given by

$$\langle S_n \rangle = \frac{1}{2} \sqrt{\frac{\omega\mu_0}{2\sigma_0}} |H_0|^2 \quad \text{Watts /m}^2.$$

$\langle S_n \rangle$ is the time averaged Poynting vector component corresponding to energy flow into the conductor surface, σ_0 is the dc conductivity of the metal wall, H_0 is the magnetic field strength at the conductor surface, and $\omega = 2\pi f$ is the circular frequency. This energy loss must be added to the energy loss in the dielectric material. The conductor losses can be taken into account by increasing the imaginary part of the wave-vector, k_2 , in Equations (11.8.5). One can write

$$\begin{aligned}V(z, t) &= [a \exp(-\alpha z) \exp(-ik_1 z) + b \exp(\alpha z) \exp(ik_1 z)] \exp(i\omega t) \\ I(z, t) &= \frac{1}{Z_0} [a \exp(-\alpha z) \exp(-ik_1 z) - b \exp(\alpha z) \exp(ik_1 z)] \exp(i\omega t)\end{aligned}\quad (11.8.6)$$

where α is an empirical parameter whose frequency dependence can be measured for a particular cable. The constants a, b in (11.8.6) must be adjusted to satisfy the boundary condition at the position of the load; i.e. at the load $Z_L = V/I$. For a cable having a

characteristic impedance Z_0 that connects a generator at $z=0$ with a load at $z=L$ this condition requires

$$\frac{Z_L}{Z_0} = \left[\frac{a \exp(-\alpha L) \exp(-ik_1 L) + b \exp(\alpha L) \exp(ik_1 L)}{a \exp(-\alpha L) \exp(-ik_1 L) - b \exp(\alpha L) \exp(ik_1 L)} \right],$$

from which

$$\frac{b}{a} = \left[\frac{Z_L - 1}{Z_0} - 1 \right] \exp(-2\alpha L) \exp(-2ik_1 L).$$

Using the previous notation $z_L = Z_L/Z_0$, and $z_G = Z_G/Z_0$, and

$$\Gamma = \frac{z_L - 1}{z_L + 1} = |\Gamma| \exp(i\theta),$$

one finds

$$z_G = \left[\frac{1 + \Gamma \exp(-2\alpha L) \exp(-2ik_1 L)}{1 - \Gamma \exp(-2\alpha L) \exp(-2ik_1 L)} \right]. \quad (11.8.7)$$

Equation (11.8.7) shows that the impedance seen by the generator approaches the characteristic impedance of the cable if the load is connected to the generator through a cable that is long compared with the attenuation length ($1/\alpha$).

Characteristics for a few representative co-axial cables are listed in Table(11.8.1), and their attenuation lengths at a number of frequencies are listed in Table(11.8.2). The length of cable for which the amplitude of a voltage pulse is attenuated to $(1/e) = 0.368$ of its original amplitude is given by $(1/\alpha)$. For example, this attenuation length is 9.8 meters for RG-8 cable at 5 GHz.

The attenuation parameter, α , for the cables listed in Table(11.8.2) are observed to be approximately proportional to $\sqrt{\omega}$, and this suggests that most of the losses in these cables is due to eddy currents in the conductors.

Cable	Outer Diam. in inches	Characteristic Impedance, Ohms	Velocity m/sec	Capacitance Farads/m
RG-8	0.405	52	1.98×10^8	96.8×10^{-12}
RG-58U	0.195	53	1.98×10^8	93.5×10^{-12}
RG-59U	0.242	75	1.98×10^8	68.9×10^{-12}
RG-62U	0.242	93	2.52×10^8	44.3×10^{-12}
RG-174U	0.100	50	1.98×10^8	98.4×10^{-12}

Table 11.8.1: Characteristics of some commonly used commercial co-axial cables. The dielectric material between the conductors is polyethylene. The data was taken from the 1985/86 catalogue of RAE Industrial Electronics Ltd., Vancouver, BC.

Cable	1.0	10.0	50.0	100	200	400	1000	3000	5000
RG-8	5.67×10^{-4}	2.08×10^{-3}	4.91×10^{-3}	7.18×10^{-3}	1.02×10^{-2}	1.55×10^{-2}	0.030	0.060	0.102
RG-58U	1.25×10^{-3}	4.72×10^{-3}	1.19×10^{-2}	1.74×10^{-2}	2.61×10^{-2}	3.97×10^{-2}	6.61×10^{-2}	0.142	0.227
RG-59U	1.25×10^{-3}	4.16×10^{-3}	9.07×10^{-3}	1.28×10^{-2}	1.85×10^{-2}	2.64×10^{-2}	4.53×10^{-2}	0.100	0.196
RG-62U	9.4×10^{-4}	3.21×10^{-3}	7.18×10^{-3}	1.02×10^{-2}	1.44×10^{-2}	2.00×10^{-2}	3.29×10^{-2}	0.070	0.113
RG-174U	8.69×10^{-3}	1.47×10^{-2}	2.49×10^{-2}	3.36×10^{-2}	4.53×10^{-2}	6.61×10^{-2}	1.13×10^{-1}	0.242	0.374

Table 11.8.2 Frequency dependence of the attenuation parameter α for some selected co-axial cables. $V(z) = V_0 \exp(-\alpha z)$. Frequencies in MHz. The data is taken from the 1985/86 catalogue of RAE Industrial Electronics Ltd., Vancouver, BC.

11.8: Transmission Line with Losses is shared under a [not declared](#) license and was authored, remixed, and/or curated by LibreTexts.